

# WASHINGTON COUNTY, TENNESSEE BOARD OF COUNTY COMMISSIONERS

## RESOLUTION NO. 25-07-12

### **RESOLUTION APPROVING AND AUTHORIZING CERTAIN EDUCATION CAPITAL PROJECTS FUND EXPENDITURES UP TO \$131,690.00 IN FY26 FOR SCHOOLS FIRE ALARM UPGRADES**

WHEREAS, the Capital Projects Funds Policy, adopted August 29, 2016 (Resolution 16-08-14), requires an enabling Resolution approved by the County Commission, identifying a specific project or use of capital funds prior to expenditure or transfer from the Capital Projects Fund; and

WHEREAS, the Director of Schools requests authorization to spend up to \$131,690.00 of budgeted funds for fire alarm upgrades as listed in Exhibit A in FY26 from the Education Capital Project Fund (177-91300-707), Education Capital Projects - Building Improvements; and

WHEREAS, at its July 10, 2025 meeting the Health Education & Welfare Committee recommended consideration and approval of this request; and

WHEREAS, at its July 15, 2025 meeting the Budget Committee recommended consideration and approval of this request to the Board of County Commissioners; now therefore

BE IT RESOLVED BY THE BOARD OF COUNTY COMMISSIONERS OF WASHINGTON COUNTY, TENNESSEE THAT:

SECTION 1. The Board of County Commissioners approves and authorizes the expenditure in an amount not to exceed \$131,690.00, from expense line item 177-91300-707, Education Capital Projects - Building Improvements, for fire alarm upgrades as listed in Exhibit A

SECTION 2. The County Purchasing Agent and County Mayor are authorized to execute all necessary documents, subject to the approval of the County Attorney.

SECTION 3. This Resolution shall take effect from and after the date on which it is approved by the County Mayor or as indicated by certification of the County Clerk, as hereinafter set forth.

---

**Introduced by Commissioner:** *Jones*

**Seconded by Commissioner:** *Davenport*


**Commissioners Voting FOR:** *Tucker, Johnson, Fitzgerald, Edens, Davenport, England, Malone, Stout, Tomita, Jones, Wexler, Huffine, Wheeler*

**Commissioners Voting AGAINST:** *None*  
**Commissioners Abstaining:** *None*  
**Commissioners Absent:** *Matherly, Carder*

---

ADOPTED BY THE COUNTY LEGISLATIVE BODY, in session duly assembled, on this the 28<sup>th</sup> day of July, 2025.

  
\_\_\_\_\_  
CHERYL STOREY, County Clerk

  
\_\_\_\_\_  
GREG MATHERLY, Chair of the Board

---

REFERRED to County Mayor this the 29 day of July 2025

  
\_\_\_\_\_  
CHERYL STOREY, County Clerk

---

APPROVED by County Mayor on this the 29 day of July 2025.

  
\_\_\_\_\_  
WILLIAM J. GRANDY, County Mayor

---

The County Mayor having declined to approve this Resolution, the same became effective on the \_\_\_ day of \_\_\_\_\_ 2025, pursuant to Tennessee Code Annotated § 5-6-107(b)(5).

\_\_\_\_\_  
CHERYL STOREY, County Clerk

---

Approved as to form by the County Attorney this 29<sup>th</sup> day of July 2025.

  
\_\_\_\_\_  
ALLYSON L. WILKINSON, County Attorney

Jerry S. Boyd  
Superintendent



**WASHINGTON**  
COUNTY SCHOOLS  
INSPIRE ★ STRIVE ★ THRIVE

**BOARD OF EDUCATION**

- Eric Barnes
- Annette Buchanan
- Keith Ervin
- Chad Fleenor
- David Hammond
- Gregg Huddleston
- Mike Masters
- Whitney Riddle
- Vince Walters

**TO: Dr. Jarrod Adams**

**FROM: Bradley Dingus, Maintenance Department (Fire Systems/Alarms)**

**DATE: February 21, 2025**

**SUBJECT: Quotes for fire alarm system updates**

The quotes listed below are for the fire alarm panel and device updates due to the existing panels being outdated and obsolete. Parts are no longer available for the systems at these schools. The systems have faults and issues constantly due to the age of the devices. It was instructed by our fire alarm company, CES Corporation, (Knoxville, TN) that these devices are to be changed out every 10 years. The current systems have been in place for over 10 years. I have spoken to the schools and they shared that the panels beep constantly in *trouble mode* because the devices have issues due to age and the weather. These older devices go in and out of trouble mode when they get cold and hot as a result of the device's age. I have listed, by priority, the quotes from CES Corporation to have the systems replaced at these schools as soon as possible.

Daniel Boone High School Main Building	\$ 44,925.00
Daniel Boone High School 900 Building	\$ 6,550.00
Daniel Boone High School 1000 Building	\$ 5,250.00
Asbury	\$ 8,865.00
Ridgeview Elementary	\$26,400.00
Grandview Elementary	\$39,700.00

---

Grand Total      \$131,690.00